



Inspired Teaching Demonstration PCS - Lead in Water Test Results



FY24 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Inspired Teaching Demonstration PCS	WS-046-001	Cooler	1	In hallway adjacent to 1st floor restrooms	High	Left	WF-022024-046001-06	5/7/24	FT-FY24-022024-046001-A	<1	FT-FY24-022024-046001-B	<1
Inspired Teaching Demonstration PCS	WS-046-002	Bottle Filler	1	In hallway adjacent to 1st floor restrooms	High	Left	WF-022024-046002-06	5/7/24	FT-FY24-022024-046002-A	<1	FT-FY24-022024-046002-B	<1
Inspired Teaching Demonstration PCS	WS-046-003	Cooler	1	In hallway adjacent to 1st floor restrooms	Low	Right	WF-022024-046003-06	5/7/24	FT-FY24-022024-046003-A	<1	FT-FY24-022024-046003-B	<1
Inspired Teaching Demonstration PCS	WS-046-004	Combo Faucet	1	In classroom 103		Left	WF-022024-046004-06	5/7/24	FT-FY24-022024-046004-A	<1	FT-FY24-022024-046004-B	<1
Inspired Teaching Demonstration PCS	WS-046-005	Combo Fountain	1	In classroom 103		Right	WF-022024-046005-06	N/A	FT-FY24-022024-046005-A	Non-operational	FT-FY24-022024-046005-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-006	Break Room	1	In teacher workroom 104			WF-022024-046006-06	5/7/24	FT-FY24-022024-046006-A	<1	FT-FY24-022024-046006-B	<1
Inspired Teaching Demonstration PCS	WS-046-007	Combo Faucet	1	In classroom 105		Left	WF-022024-046007-06	5/7/24	FT-FY24-022024-046007-A	<1	FT-FY24-022024-046007-B	<1
Inspired Teaching Demonstration PCS	WS-046-008	Combo Fountain	1	In classroom 105		Right	WF-022024-046008-06	N/A	FT-FY24-022024-046008-A	Non-operational	FT-FY24-022024-046008-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-009	Health Suite	1	In health suite 104B			WF-022024-046009-06	5/7/24	FT-FY24-022024-046009-A	1.1	FT-FY24-022024-046009-B	<1
Inspired Teaching Demonstration PCS	WS-046-010	Combo Faucet	1	In classroom 108		Left	WF-022024-046010-06	5/7/24	FT-FY24-022024-046010-A	<1	FT-FY24-022024-046010-B	<1
Inspired Teaching Demonstration PCS	WS-046-011	Combo Fountain	1	In classroom 108		Right	WF-022024-046011-06	N/A	FT-FY24-022024-046011-A	Non-operational	FT-FY24-022024-046011-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-012	Combo Faucet	1	In classroom 109		Left	WF-022024-046012-06	5/7/24	FT-FY24-022024-046012-A	<1	FT-FY24-022024-046012-B	<1
Inspired Teaching Demonstration PCS	WS-046-013	Combo Fountain	1	In classroom 109		Right	WF-022024-046013-06	N/A	FT-FY24-022024-046013-A	Non-operational	FT-FY24-022024-046013-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-014	Combo Faucet	1	In classroom 110		Left	WF-022024-046014-06	5/7/24	FT-FY24-022024-046014-A	1.4	FT-FY24-022024-046014-B	<1
Inspired Teaching Demonstration PCS	WS-046-015	Combo Fountain	1	In classroom 110		Right	WF-022024-046015-06	N/A	FT-FY24-022024-046015-A	Non-operational	FT-FY24-022024-046015-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-016	Combo Faucet	1	In classroom 111		Left	WF-022024-046016-06	5/7/24	FT-FY24-022024-046016-A	<1	FT-FY24-022024-046016-B	<1
Inspired Teaching Demonstration PCS	WS-046-017	Combo Fountain	1	In classroom 111		Right	WF-022024-046017-06	N/A	FT-FY24-022024-046017-A	Non-operational	FT-FY24-022024-046017-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-019	Combo Fountain	2	In classroom 216		Right	WF-022024-046019-06	N/A	FT-FY24-022024-046019-A	Non-operational	FT-FY24-022024-046019-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-021	Combo Fountain	2	In classroom 214		Right	WF-022024-046021-06	N/A	FT-FY24-022024-046021-A	Non-operational	FT-FY24-022024-046021-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-022	Break Room	2	In teacher workroom 212			WF-022024-046022-06	5/7/24	FT-FY24-022024-046022-A	<1	FT-FY24-022024-046022-B	<1
Inspired Teaching Demonstration PCS	WS-046-024	Combo Fountain	2	In classroom 204		Right	WF-022024-046024-06	N/A	FT-FY24-022024-046024-A	Non-operational	FT-FY24-022024-046024-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-026	Combo Fountain	2	In classroom 202		Right	WF-022024-046026-06	N/A	FT-FY24-022024-046026-A	Non-operational	FT-FY24-022024-046026-B	Non-operational
Inspired Teaching Demonstration PCS	WS-046-027	Cooler	2	In hallway adjacent to 2nd floor restrooms	High	Left	WF-022024-046027-06	5/7/24	FT-FY24-022024-046027-A	<1	FT-FY24-022024-046027-B	<1
Inspired Teaching Demonstration PCS	WS-046-028	Bottle Filler	2	In hallway adjacent to 2nd floor restrooms	High	Left	WF-022024-046028-06	5/7/24	FT-FY24-022024-046028-A	<1	FT-FY24-022024-046028-B	<1
Inspired Teaching Demonstration PCS	WS-046-029	Cooler	2	In hallway adjacent to 2nd floor restrooms	Low	Right	WF-022024-046029-06	5/7/24	FT-FY24-022024-046029-A	<1	FT-FY24-022024-046029-B	<1
Inspired Teaching Demonstration PCS	WS-046-030	Cooler	3	In hallway adjacent to 3rd floor restrooms	High	Left	WF-022024-046030-06	5/7/24	FT-FY24-022024-046030-A	<1	FT-FY24-022024-046030-B	<1
Inspired Teaching Demonstration PCS	WS-046-031	Bottle Filler	3	In hallway adjacent to 3rd floor restrooms	High	Left	WF-022024-046031-06	5/7/24	FT-FY24-022024-046031-A	<1	FT-FY24-022024-046031-B	<1
Inspired Teaching Demonstration PCS	WS-046-032	Cooler	3	In hallway adjacent to 3rd floor restrooms	Low	Right	WF-022024-046032-06	5/7/24	FT-FY24-022024-046032-A	<1	FT-FY24-022024-046032-B	<1
Inspired Teaching Demonstration PCS	WS-046-033	Break Room	3	In teacher workroom 317			WF-022024-046033-06	5/7/24	FT-FY24-022024-046033-A	<1	FT-FY24-022024-046033-B	<1
Inspired Teaching Demonstration PCS	WS-046-034	Food Prep Sink	1	In kitchen 132		Left	WF-022024-046034-06	5/7/24	FT-FY24-022024-046034-A	1.6	FT-FY24-022024-046034-B	<1
Inspired Teaching Demonstration PCS	WS-046-035	Food Prep Sink	1	In kitchen 132		Right	WF-022024-046035-06	5/7/24	FT-FY24-022024-046035-A	2.9	FT-FY24-022024-046035-B	<1